

7/15/200

| <u>AREA</u> | | <u>FAILURE</u> | <u>PROBLEM</u> | <u>PROBLEM DESCRIPTION</u> | <u>FINISH DATE</u> |
|-----------------|----------|----------------|----------------|---|--------------------|
| WSSTANDB | | SSGRAVMAIN | BLOCKAGE | backed up sewage @ 2725 Wendy La. / Creek Park | July 11, 2009 |
| WSSTANDB | 1 | | | | |
| WSZONE1 | | SSGRAVMAIN | BLOCKAGE | manhole overflowing @ 2160 Cannon Way | July 13, 2009 |
| WSZONE1 | | SSGRAVMAIN | BLOCKAGE | Manhole overflowing 3170 Weatherbyrne Rd | July 08, 2009 |
| WSZONE1 | 2 | | | | |
| WSZONE2 | | SSGRAVMAIN | BLOCKAGE | sewer spill @ six flags dr & gold mine rd | July 09, 2009 |
| WSZONE2 | 1 | | | | |
| WSZONE3 | | SSGRAVMAIN | BLOCKAGE | manhole overflowing @ 1625 Ernest Barrett Pky | July 08, 2009 |
| WSZONE3 | 1 | | | | |
| WSZONE4 | | SSGRAVMAIN | BLOCKAGE | Flush Mian @ Edgemere Dr | July 08, 2009 |
| WSZONE4 | | SSGRAVMAIN | BLOCKAGE | flush main@ 152 edgewood dr | July 14, 2009 |
| WSZONE4 | 2 | | | | |
| WSZONE1 | | SSGRAVMAIN | BROKEN | cctv_child - push camera main line @ 3170 Weather | July 14, 2009 |
| WSZONE1 | 1 | | | | |
| WSZONE4 | | SSGRAVMAIN | BROKEN | Check & Investigate @ 491 Broadstone Way | July 09, 2009 |
| WSZONE4 | | SSGRAVMAIN | BROKEN | KM09Z4008 replace main @2514 east piedmont rd | July 13, 2009 |
| WSZONE4 | 2 | | | | |
| WSZONE2 | | SSGRAVMAIN | CCTV | Camera Truck Main Z3 @ 2859 Overlook Pkwy | July 09, 2009 |
| WSZONE2 | 1 | | | | |
| WSZONE3 | | SSGRAVMAIN | CCTV | Assist 2429 @ 2859 Overlook Pkwy | July 09, 2009 |
| WSZONE3 | 1 | | | | |
| WSSWING | | SSMANHOLE | BLOCKAGE | MANHOLE OVERFLOWING @ 4775 AUSTELL RD | July 10, 2009 |
| WSSWING | | SSMANHOLE | BLOCKAGE | man hole over flowing @ 2751 bentley pl | July 09, 2009 |
| WSSWING | 2 | | | | |
| WSZONE2 | | SSMANHOLE | BLOCKAGE | Inspect Manhole @ 140 Silver mine Trail. | July 10, 2009 |
| WSZONE2 | 1 | | | | |
| WSZONE1 | | SSMANHOLE | BROKECONCRETE | Broken m/h asphalt @ @357 Battle Woods Trl | July 13, 2009 |
| WSZONE1 | 1 | | | | |
| WSZONE4 | | SSMANHOLE | BROKECONCRETE | Bepair manhole @ 3590 Bramblewood Way | July 10, 2009 |
| WSZONE4 | | SSMANHOLE | BROKECONCRETE | Boad Cut Size - 6x6 @ Sandy Plains Rd | July 10, 2009 |

7/15/200

| <u>AREA</u> | | <u>FAILURE</u> | <u>PROBLEM</u> | <u>PROBLEM DESCRIPTION</u> | <u>FINISH DATE</u> |
|-----------------|----------|----------------|----------------|---|--------------------|
| WSZONE4 | | SSMANHOLE | BROKECONCRET | Digup - Change out M-H rings&covers to b/d Z4 460 | July 08, 2009 |
| WSZONE4 | 3 | | | | |
| WSZONE4 | | SSMANHOLE | OVERFLOW | man hole over flowing @2071 mulkey rd | July 10, 2009 |
| WSZONE4 | 1 | | | | |
| WSZONE2 | | SSTAP | BLOCKAGE | back up @ 450 Hilltop Circle Ext | July 10, 2009 |
| WSZONE2 | | SSTAP | BLOCKAGE | back up @ 1820 South Cobb Industrial Blvd | July 10, 2009 |
| WSZONE2 | 2 | | | | |
| WSZONE3 | | SSTAP | BLOCKAGE | sewer back up @ 1435 Waterford Green Dr | July 08, 2009 |
| WSZONE3 | 1 | | | | |
| WSZONE4 | | SSTAP | BLOCKAGE | sewer backup @ 1155 silvertown ct./silverstone trl. | July 14, 2009 |
| WSZONE4 | 1 | | | | |
| WSZONE3 | | SSTAP | BROKEN | Digup - Dig up tap 3000 Wellington Ct. | July 10, 2009 |
| WSZONE3 | 1 | | | | |
| WSHYDRAN | | WHYDRANT | LEAKING | leaking from bonnet 16C | July 09, 2009 |
| WSHYDRAN | 1 | | | | |
| WSHYDRAN | | WHYDRANT | NONOP | 2 1/2" connection damaged and can't get cap or cou | July 08, 2009 |
| WSHYDRAN | 1 | | | | |
| WSZONE2 | | WMAIN | BROKEN | water leak at 201 concord rd | July 08, 2009 |
| WSZONE2 | 1 | | | | |
| WSZONE4 | | WMAIN | BROKEN | Locate / Replace Valve @ 2181 Deep Woods Way | July 08, 2009 |
| WSZONE4 | 1 | | | | |
| WSZONE2 | | WMAIN | LEAK | Main break @ 2343 Weslan Dr | July 10, 2009 |
| WSZONE2 | 1 | | | | |
| WSZONE4 | | WMAIN | LEAK | WATER LEAK AT 2157 DEEP WOODS WAY | July 13, 2009 |
| WSZONE4 | 1 | | | | |
| WSZONE4 | | WMETER | LEAK | leak @ meter on cust side @ 2157 Heritage trace la | July 14, 2009 |
| WSZONE4 | 1 | | | | |
| WSSWING | | WSVCLINE | LEAK | water leak @ 4109 West Pointe Dr | July 09, 2009 |
| WSSWING | | WSVCLINE | LEAK | muddy water @ 1123 Bugler Ct | July 08, 2009 |
| WSSWING | | WSVCLINE | LEAK | water leak @ 2210 Misty Lane / Oakdale Rd. | July 10, 2009 |

7/15/200

| <u>AREA</u> | | <u>FAILURE</u> | <u>PROBLEM</u> | <u>PROBLEM DESCRIPTION</u> | <u>FINISH DATE</u> |
|----------------|----------|----------------|----------------|--|--------------------|
| WSSWING | | WSVCLINE | LEAK | leak @ meter 4763 howard dr near brownsville rd | July 11, 2009 |
| WSSWING | | WSVCLINE | LEAK | water leak @ 1629 virginia pl | July 09, 2009 |
| WSSWING | 5 | | | | |
| WSZONE1 | | WSVCLINE | LEAK | Repair shortside service leak @ 2801 Bent Creek Dr | July 10, 2009 |
| WSZONE1 | | WSVCLINE | LEAK | Service Leak at 1465 Kennesaw-Due West Rd. | July 09, 2009 |
| WSZONE1 | | WSVCLINE | LEAK | Repair shortside service leak @ 415 Wiscassett Wa | July 13, 2009 |
| WSZONE1 | 3 | | | | |
| WSZONE2 | | WSVCLINE | LEAK | SERVICE LINE LEAK @ 605 FACTORY SHOALS C | July 08, 2009 |
| WSZONE2 | | WSVCLINE | LEAK | Digup - Repair Long side Service @ 1497 Mill Creek | July 08, 2009 |
| WSZONE2 | | WSVCLINE | LEAK | Repair service line @ 2055 Mulkey Road | July 13, 2009 |
| WSZONE2 | | WSVCLINE | LEAK | Repair longside service @ 5021 White Blvd. | July 14, 2009 |
| WSZONE2 | | WSVCLINE | LEAK | Cut line @ 3895 Jiles Rd | July 09, 2009 |
| WSZONE2 | | WSVCLINE | LEAK | Repair Longside Service @ 1629 Virginia Place | July 14, 2009 |
| WSZONE2 | 6 | | | | |
| WSZONE4 | | WSVCLINE | LEAK | water leak @ 4333 Arbor Bridge Dr | July 10, 2009 |
| WSZONE4 | | WSVCLINE | LEAK | Medium leak @ 3284 Devaughn Dr. | July 14, 2009 |
| WSZONE4 | | WSVCLINE | LEAK | Replace services @ 3918 potomac dr | July 09, 2009 |
| WSZONE4 | | WSVCLINE | LEAK | water leak @ 4716 North View Rd | July 08, 2009 |
| WSZONE4 | | WSVCLINE | LEAK | water leak @ 2841 Interlaken Dr | July 08, 2009 |
| WSZONE4 | 5 | | | | |

| <u>AREA</u> | <u>FAILURE</u> | <u>PROBLEM</u> | <u>PROBLEM DESCRIPTION</u> | <u>FINISH DATE</u> |
|-------------|----------------|----------------|-----------------------------|--------------------|
| | | | Total Number of Work Orders | 51 |

| <u>AREA</u> | <u>FAILURE</u> | <u>PROBLEM</u> | <u>PROBLEM DESCRIPTION</u> | <u>FINISH DATE</u> |
|-------------|----------------|----------------|----------------------------|--------------------|
|-------------|----------------|----------------|----------------------------|--------------------|